



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3416524-075-2024

MDE OFFICIAL CONTACTED: EVELYN S.

DATA CALLED IN BY: 4581

DATE: 11/22/2024 AT 09:40AM

WORK ORDER(S): 3416524 3416514

EST DATE AND TIME SSO BEGAN: 11/22/2024 08:48AM DURATION: 3.20 HRS  
DATE AND TIME SSO ENDED: 11/22/2024 12:00PM

SOURCE-AIR REL VLV/FORCE M SS16013092 WATER BODY AFFECTED-WATTS BRANCH

CLOSEST STREET ADDRESS: 12620 GREENBRIER RD 20854  
COUNTY/PAGE/GRID: M 5163 B10 TOWN/CITY: POTOMAC

CAUSE: DEFECTIVE MATERIAL EST OVERFLOW VOLUME: 500 GAL  
UPON ARRIVAL, THE CREW FOUND A BROKEN FORCE MAIN OVERFLOWING  
A TOTAL OF 500 GALLONS, ONTO THE GRASSY AREA NEAR THE BREAK. THE CREW  
TURNED OFF THE VALVES AT VV#91R7 AND VV#92R, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:  
WET WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:  
THIS EVENT OCCURRED FROM A FORCE MAIN AND IS THEREFORE NOT CCTVABLE.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:  
VISIBLE SOLIDS REMOVED

THE CREW REMOVED THE VISIBLE SOLIDS FORM THE AREA.

NOTIFICATIONS MADE:  
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 12617 GREENBRIAR ROAD.