



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3417515-118-2024

MDE OFFICIAL CONTACTED: CHRIS SHAFFNER

DATA CALLED IN BY: BRANDON T MCCREA DATE: 11/30/2024 AT 12:55PM

WORK ORDER(S): 3417515 3417513

EST DATE AND TIME SSO BEGAN: 11/30/2024 10:26AM DURATION: 2.82 HRS
DATE AND TIME SSO ENDED: 11/30/2024 01:15PM

SOURCE-OVERFLOWING MH MH17026010 WATER BODY AFFECTED-PATUXENT RIVER

CLOSEST STREET ADDRESS: 8717 MULBERRY ST 20707
COUNTY/PAGE/GRID: P 5169 D07 TOWN/CITY: LAUREL

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 338 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 010U OVERFLOWING INTO THE SURROUNDING GRASSY AREA AROUND THE MANHOLE, AND INTO A NEARBY TRIBUTARY THAT OUTFALLS INTO THE PARKWAY BASIN. THE CREW JETTED FROM MANHOLE 009M TO 010U, A TOTAL OF 116', AND RELIEVED A HEAVY ROOTS AND WIPES BLOCKAGE, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DISCOLORATION NOTICEABLE ODOR
PUBLIC ACCESS PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 14000 R/W RAILROAD AVENUE.

SIGNS POSTED: 2 POST DATE: 11/30/2024