



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3421393-073-2024

MDE OFFICIAL CONTACTED: CHRIS

DATA CALLED IN BY: PATRICIA A HILL

DATE: 12/13/2024 AT 10:12PM

WORK ORDER(S): 3421393 3421353

EST DATE AND TIME SSO BEGAN: 12/13/2024 03:36PM DURATION: 4.40 HRS
DATE AND TIME SSO ENDED: 12/13/2024 08:00PM

SOURCE-CLEAN OUT 00230371700 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 14500 OLD MILL RD 20772
COUNTY/PAGE/GRID: P 5652 K10 TOWN/CITY: UPPER MARLBORO

CAUSE: ROOTS & GREASE EST OVERFLOW VOLUME: 240 GAL
UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT OVERFLOWING
ONTO THE GRASSY AREA AROUND THE CLEANOUT. THE CREW JETTED FROM
MANHOLE 012U TO 013M, A TOTAL OF 220' AND RELIEVED A MEDIUM ROOTS
AND GREASE OBSTRUCTION AT 110', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER DISCOLORATION
NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME AROUND THE GRASSY AREA AROUND THE PROPERTY LINE CLEANOUT.

NOTIFICATIONS MADE:
PG COUNTY MUNICIPALITIES MD DEPARTMENT OF ENVIRONMENT
PG COUNTY HEALTH DEPT

SIGNS POSTED: 3 POST DATE: 12/16/2024