



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3421478-073-2024

MDE OFFICIAL CONTACTED: JAMES LYONS

DATA CALLED IN BY: MARVIN BAILEY DATE: 12/14/2024 AT 02:55PM

WORK ORDER(S): 3421478 3421465

EST DATE AND TIME SSO BEGAN: 12/14/2024 11:58AM DURATION: 2.45 HRS
DATE AND TIME SSO ENDED: 12/14/2024 02:25PM

SOURCE-CLEAN OUT 00130373400 WATER BODY AFFECTED-BROAD CREEK

CLOSEST STREET ADDRESS: 1507 STIRLING CT 20744
COUNTY/PAGE/GRID: P 5765 C03 TOWN/CITY: FORT WASHINGTON

CAUSE: ROOTS EST OVERFLOW VOLUME: 10 GAL

UPON ARRIVAL, THE CREW FOUND THE PROPERTY LINE CLEANOUT HOLDING, AND HAD RECENTLY OVERFLOWED ONTO THE GRASSY AREA AROUND THE CLEANOUT A TOTAL OF 10 GALLONS. THE CREW JETTED FROM MH026U TO 028M, A TOTAL OF 166', RELIEVING A MEDIUM ROOT OBSTRUCTION AT 67', AND 110FT, TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION
NOTICEABLE ODOR PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE PROPERTY LINE CLEANOUT.

NOTIFICATIONS MADE:

PG COUNTY MUNICIPALITIES PG COUNTY HEALTH DEPT
MD DEPARTMENT OF ENVIRONMENT

SIGNS POSTED: 1 POST DATE: 12/16/2024