



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3426641-118-2025

MDE OFFICIAL CONTACTED: JORDAN RHOOMS

DATA CALLED IN BY: MARVIN BAILEY

DATE: 01/04/2025 AT 02:55PM

WORK ORDER(S): 3426641 3426636

EST DATE AND TIME SSO BEGAN: 01/04/2025 01:14PM DURATION: 1.27 HRS

DATE AND TIME SSO ENDED: 01/04/2025 02:30PM

SOURCE-OVERFLOWING MH MH14198039 WATER BODY AFFECTED-WESTERN BRANCH

CLOSEST STREET ADDRESS: 7931 MANDAN RD 20770

COUNTY/PAGE/GRID: P 5411 B01 TOWN/CITY: GREENBELT

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 381 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 039M OVERFLOWING AT 5GPM, INTO A NEARBY STORM DRAIN THAT OUTFALLS INTO WESTERN BRANCH. THE CREW JETTED FROM MANHOLE 038M TO 039M, A TOTAL OF 245', AND RELIEVED GREASE AND WIPES AT 210', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

FLUSHED BACK INTO MANHOLE VISIBLE SOLIDS REMOVED

THE CREW FLUSHED SOLIDS BACK INTO THE MANHOLE, AND WASHED DOWN THE AREA WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 7915 MANDAN ROAD.

SIGNS POSTED: 2 POST DATE: 01/04/2025