



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3426643-118-2025

MDE OFFICIAL CONTACTED: JORDAN RHOOMS

DATA CALLED IN BY: CAROLINA RUIZ

DATE: 01/04/2025 AT 04:50PM

WORK ORDER(S): 3426643 3426637

EST DATE AND TIME SSO BEGAN: 01/04/2025 01:19PM DURATION: 2.43 HRS

DATE AND TIME SSO ENDED: 01/04/2025 03:45PM

SOURCE-OVERFLOWING MH MH07009004 WATER BODY AFFECTED-CABIN JOHN

CLOSEST STREET ADDRESS: 6416 83RD PL 20818

COUNTY/PAGE/GRID: M 5406 C05 TOWN/CITY: CABIN JOHN

CAUSE: ROOTS EST OVERFLOW VOLUME: 437 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 004M OVERFLOWING APPROXIMATELY 3GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO THE C&O CANAL IN THE CABIN JOHN BASIN. THE CREW JETTED FROM MANHOLE 003M TO 004M A TOTAL OF 306', AND RELIEVED HEAVY ROOTS AT 142', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DISCOLORATION NOTICEABLE ODOR
PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 6414 83RD PLACE.

SIGNS POSTED: 6 POST DATE: 01/04/2025