



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3432515-073-2025

MDE OFFICIAL CONTACTED: EVELYN STARVROU

DATA CALLED IN BY: BRANDON T MCCREA DATE: 01/29/2025 AT 09:50AM

WORK ORDER(S): 3432515 3432462

EST DATE AND TIME SSO BEGAN: 01/29/2025 07:54AM DURATION: 3.10 HRS
DATE AND TIME SSO ENDED: 01/29/2025 11:00AM

SOURCE-CLEAN OUT 00057736100 WATER BODY AFFECTED-LITTLE FALLS

CLOSEST STREET ADDRESS: 4905 BROOKWAY DR 20816
COUNTY/PAGE/GRID: M 5407 B08 TOWN/CITY: BETHESDA

CAUSE: UNKNOWN EST OVERFLOW VOLUME: 93 GAL
UPON ARRIVAL, THE CREW FOUND AN UNIDENTIFIED CLEANOUT OVERFLOWING
0.5 GPM, ONTO THE PAVEMENT, AND INTO A NEARBY STORM DRAIN THAT
OUTFALLS INTO THE LITTLE FALLS BASIN. A WSSC CONTRACTOR REMOVED THE
UNIDENTIFIED CLEANOUT, AND INSTALLED 3' OF PVC PIPE, TO END THE
EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER NOTICEABLE ODOR
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

THE CREW WASHED DOWN THE PAVEMENT WITH DECHLORINATED WATER.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 3 POST DATE: 01/29/2025