



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3434748-118-2025

MDE OFFICIAL CONTACTED: KELLY KITCHENS

DATA CALLED IN BY: PARIS S JORDAN

DATE: 02/08/2025 AT 03:45PM

WORK ORDER(S): 3434748 3434743

EST DATE AND TIME SSO BEGAN: 02/08/2025 11:48AM DURATION: 3.70 HRS
DATE AND TIME SSO ENDED: 02/08/2025 03:30PM

SOURCE-OVERFLOWING MH MH15022044 WATER BODY AFFECTED-SENECA CREEK

CLOSEST STREET ADDRESS: 11546 SUMMER OAK DR 20874
COUNTY/PAGE/GRID: M 5047 A05 TOWN/CITY: GERMANTOWN

CAUSE: GREASE EST OVERFLOW VOLUME: 666 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 044U OVERFLOWING 3GPM INTO THE FOREST AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 055U TO MANHOLE 034U A TOTAL OF 430' AND HIT AND RELIEVED HARD GREASE BLOCKAGE AT 230', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
WET WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE

LIME COULD NOT BE APPLIED DUE TO HEAVY ICE RAIN.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORGINALLY REPORTED AS 18765 SUMMER OAK COURT.

SIGNS POSTED: 3 POST DATE: 02/08/2025