



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3434973-118-2025

MDE OFFICIAL CONTACTED: JILLAN HOHMAN

DATA CALLED IN BY: MARVIN BAILEY

DATE: 02/10/2025 AT 05:16PM

WORK ORDER(S): 3434973 3434928

EST DATE AND TIME SSO BEGAN: 02/10/2025 01:02PM DURATION: 2.22 HRS

DATE AND TIME SSO ENDED: 02/10/2025 03:15PM

SOURCE-OVERFLOWING MH MH02008053 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 2843 POWDER MILL RD 20783

COUNTY/PAGE/GRID: P 5287 G06 TOWN/CITY: HYATTSVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 67 GAL

UPON ARRIVAL, THE CREW FOUND MANHOLE 053K OVERFLOWING APPROXIMATELY 0.5 GPM ONTO A GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 054U TO 053K, AND HIT AND RELIEVED A HARD ROOT BLOCKAGE AT 5', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER NOTICEABLE ODOR

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME RAKED AREA
VISIBLE SOLIDS REMOVED

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT PG COUNTY HEALTH DEPT
PG COUNTY MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 02/10/2025