



# WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3445521-118-2025

MDE OFFICIAL CONTACTED: MDE EVELYN STAVROU

DATA CALLED IN BY: MARVIN BAILEY

DATE: 03/04/2025 AT 12:55PM

WORK ORDER(S): 3445521 3445497

EST DATE AND TIME SSO BEGAN: 03/04/2025 11:19AM DURATION: 2.18 HRS  
DATE AND TIME SSO ENDED: 03/04/2025 01:30PM

SOURCE-OVERFLOWING MH MH05144002 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 14529 PARKVALE RD 20853  
COUNTY/PAGE/GRID: M 5165 B06 TOWN/CITY: ROCKVILLE

CAUSE: ROOTS EST OVERFLOW VOLUME: 131 GAL  
UPON ARRIVAL, THE CREW FOUND MANHOLE 002M OVERFLOWING APPROXIMATELY  
1GPM, ONTO THE GRASSY AREA AROUND THE MANHOLE, AND INTO ROCK CREEK.  
THE CREW REMOVED 3 GALLONS OF ROOTS FROM THE INLET OF MANHOLE 044M, TO  
END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:

DRY WEATHER DISCOLORATION  
PUBLIC ACCESS PUBLIC USE OBSERVED  
VISIBLE SOLIDS, IN STREAM

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:

THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE  
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED  
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE  
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:

LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:

MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY  
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/04/2025