



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3446191-118-2025

MDE OFFICIAL CONTACTED: FELIPE

DATA CALLED IN BY: PARIS S JORDAN

DATE: 03/08/2025 AT 04:10PM

WORK ORDER(S): 3446191 3446182

EST DATE AND TIME SSO BEGAN: 03/08/2025 01:25PM DURATION: 1.83 HRS
DATE AND TIME SSO ENDED: 03/08/2025 03:15PM

SOURCE-OVERFLOWING MH MH06032082 WATER BODY AFFECTED-SLIGO CREEK

CLOSEST STREET ADDRESS: 8707-11 ARLISS ST 20901
COUNTY/PAGE/GRID: M 5286 K10 TOWN/CITY: SILVER SPRING

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 110 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 082M OVERFLOWING APPROXIMATELY
1GPM ONTO A GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM
MANHOLE 086M TO 082M A TOTAL OF 43', AND RELIEVED GREASE AND WIPES
AT 1', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
VISIBLE SOLIDS REMOVED

THE CREW REMOVED ALL VISIBLE SOLIDS.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

SIGNS POSTED: 2 POST DATE: 03/08/2025