



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3447191-118-2025

MDE OFFICIAL CONTACTED: JOANNE HOHAN #168958

DATA CALLED IN BY: CAROLINA RUIZ DATE: 03/13/2025 AT 09:15PM

WORK ORDER(S): 3447191 3447182

EST DATE AND TIME SSO BEGAN: 03/13/2025 06:47PM DURATION: 4.22 HRS
DATE AND TIME SSO ENDED: 03/13/2025 11:00PM

SOURCE-OVERFLOWING MH MH02044026 WATER BODY AFFECTED-PAINT BRANCH

CLOSEST STREET ADDRESS: 1 BALLINGER CT 20866
COUNTY/PAGE/GRID: M 5167 K06 TOWN/CITY: BURTONSVILLE

CAUSE: ROOTS AND WIPES EST OVERFLOW VOLUME: 253 GAL
UPON ARRIVAL THE CREW FOUND MANHOLE 026U OVERFLOWING APPROXIMATELY
1GPM ONTO A NEARBY POND THAT FALLS INTO PAINT BRANCH BASIN. THE CREW
JETTED FROM MANHOLE 289U TO 026U A TOTAL OF 275', HIT AND RELIEVED
ROOTS AND WIPES AT 150', 175', AND 250', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
LIME

THE CREW SPREAD LIME IN THE GRASSY AREA AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT MONTGOMERY CO MUNICIPALITIES
DEP-MONTGOMERY COUNTY

SIGNS POSTED: 4 POST DATE: 03/14/2025