



WASHINGTON SUBURBAN SANITARY COMMISSION SANITARY SEWER OVERFLOW WRITTEN REPORT

3447990-118-2025

MDE OFFICIAL CONTACTED: MS.EVELYN

DATA CALLED IN BY: DIARRA K MACKALL DATE: 03/19/2025 AT 11:58AM

WORK ORDER(S): 3447990 3447983

EST DATE AND TIME SSO BEGAN: 03/19/2025 11:07AM DURATION: 3.80 HRS
DATE AND TIME SSO ENDED: 03/19/2025 02:55PM

SOURCE-OVERFLOWING MH MH05154075 WATER BODY AFFECTED-ROCK CREEK

CLOSEST STREET ADDRESS: 15325 CARROLTON RD 20853
COUNTY/PAGE/GRID: M 5165 F03 TOWN/CITY: ROCKVILLE

CAUSE: GREASE AND WIPES EST OVERFLOW VOLUME: 456 GAL
UPON ARRIVAL, THE CREW FOUND MANHOLE 075U OVERFLOWING AT 2 GPM ONTO
THE GRASSY AREA AROUND THE MANHOLE. THE CREW JETTED FROM MANHOLE 076M,
THROUGH 075U, TO 074U, A TOTAL OF 469', AND RELIEVED GREASE AND WIPES
AT 399', TO END THE EVENT.

IMPACTS UPON PUBLIC HEALTH AND STATE WATERS:
DRY WEATHER PUBLIC ACCESS
PUBLIC USE OBSERVED

STEPS TAKEN OR PLANNED TO REDUCE, ELIMINATE AND PREVENT RECURRENCE:
THE PROBLEM WITH THIS SEWER LINE HAS BEEN REFERRED TO LINE BLOCKAGE
ANALYSIS (LBA) FOR REVIEW. A FOLLOW-UP INVESTIGATION WILL BE CONDUCTED
TO DETERMINE WHAT MEASURES SHOULD BE TAKEN TO REDUCE OR ELIMINATE
THE CHANCE OF THIS LINE OVERFLOWING AGAIN.

MEASURES INITIATED/TAKEN TO MINIMIZE IMPACT:
FLUSHED BACK INTO MANHOLE VISIBLE SOLIDS REMOVED
LIME

THE CREW REMOVED VISIBLE SOLIDS, AND SPREAD LIME IN THE GRASSY AREA
AROUND THE MANHOLE.

NOTIFICATIONS MADE:
MD DEPARTMENT OF ENVIRONMENT DEP-MONTGOMERY COUNTY
MONTGOMERY CO MUNICIPALITIES

THIS EVENT WAS ORIGINALLY REPORTED AS 15317 CARROLTON RD.

SIGNS POSTED: 5 POST DATE: 03/20/2025