


NOTES:

1. ANODES PLACED AT SAME DEPTH AS THE BOTTOM OF PIPE AND AT A MINIMUM OF 12" FROM EDGE OF PIPE, SEE DETAIL C/7.12.
2. DO NOT THERMITE WELD TO PVC PIPE.

WASHINGTON  
SUBURBAN  
SANITARY  
COMMISSION

APPROVED: 9/29/16  
  
Chief Engineer

STANDARD DETAIL  
PVC AWWA C-900 PIPE  
4-INCH TO 12-INCH  
ANODE PROTECTION FOR  
SERVICE SADDLE

C  
7.11